

Emission Test Certificate

Monday 27th May 2019

Supplier: Airstep Flooring Pty Ltd (20 South Gippsland Highway, Dandenong, VIC, 3175, Australia)

Sample Description: Multilayer Hybrid Flooring

Date Tested: May 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Multilayer Hybrid Flooring</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.180 mg/m²/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: ≤0.1 mg/m²/hr</p>	<p align="center">Formaldehyde Emission Rate: 0.015 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190485