AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Air Step

20 South Gippsland Highway Dandenong South VIC 3175 **Test Number** : 23-001235

Issue Date : 28/04/2023 Print Date : 4/05/2023

Sample Description Clients Ref: "12mm Laminate with 2mm Timber Max Underlay"

Laminate flooring tested on Airstep Timber Max Underlay

Colour : Timber look End Use : Flooring

Nominal Composition: Melamine, Wood Pulp

Nominal Thickness: 12mm



294404 63785 Page 1 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.





Fiona McDonald

APPROVED SIGNATORY

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Air Step Test Number: 23-001235

20 South Gippsland Highway Issue Date : 28/04/2023

Dandenong South VIC 3175 Print Date : 4/05/2023

AS ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source

Date of Sample Arrival 29-03-2023

Date Tested 28-04-2023

24.5 / 55.5 4	20-04-2023				
CHF Value	1	2	3	Mean	
Length	6.3	6.6	6.5	6.5	kW/m²
Width	6.5	-	-	-	kW/m²
HF-30 Value	1	2	3	Mean	
Length	8.0	6.8	7.6	7.5	kW/m²
Width	7.4	-	-	-	kW/m²
Smoke Value	1	2	3	Mean	
Length	32	51	38	40	%.min
Width	50	-	-	-	%.min

294404 63785 Page 2 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald

APPROVED SIGNATORY



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Air Step

20 South Gippsland Highway Dandenong South VIC 3175 **Test Number** : 23-001235 **Issue Date** : 28/04/2023

Issue Date : 28/04/2023 Print Date : 4/05/2023

Observation

Blistering

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

Each specimen was loose laid over Airstep Timbermax underlay and 6mm thick fibre reinforced cement board and clamped prior to testing

294404 63785 Page 3 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald

APPROVED SIGNATORY